

Gilham Elementary School

Eugene SD 4J

Lane_sch08A

Building Type	County
School	Lane
Street	
3307 Honeywood St	
City	State Zip
Eugene	OR 97401
Latitude	Longitude
44.09953	123.07659
Tracking Code	Inspection Date
Structural Engineering Report 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Gilham Elementary School

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



Oregon Geology

Gilham Elementary School

Lane_sch08A

Enrollment 535	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built
Total Area (square ft) 74500	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries