

# Harris Elementary School

Eugene SD 4J

Lane\_sch09A

Building Type	County	
School	Lane	
Street		
1150 E 29th Ave		
City	State	Zip
Eugene	OR	97403
Latitude	Longitude	
44.02513	123.07594	
Tracking Code	Inspection Date	
RVS in 2006	1/29/2007	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Harris Elementary School

## Final RVS Score

Final Type	Final Score
W2	1.3

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Harris Elementary School

Lane\_sch09A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
215		1949	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
40613	1	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Torsion: Eccentric Stiffness		Building On Hill or Sloped Site	
None		None	
Falling Hazards		Poor Conditions	
Other: Brick Veneer		None	
Unreinforced Chimneys		None	
Other: Ornamental Hazard Over Exit		None	
W Vertical Irregularity Primary	SW Primary Structural Type	SE Plan Irregularity Secondary	
E Elevation View	E Plan Irregularity Primary	NE Falling Hazard	
N Building Name	NW Basement		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Harris Elementary School

Eugene SD 4J

Lane\_sch09B

Building Type School	County Lane	
Street 1150 E 29th Ave		
City Eugene	State OR	Zip 97403
Latitude 44.02512	Longitude 123.07548	
Tracking Code RVS in 2006	Inspection Date 1/29/2007	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Harris Elementary School

## Final RVS Score

Final Type	Final Score
W2	1.3

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Harris Elementary School

Lane\_sch09B

Enrollment 215	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 40613	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE	Plan Irregularity Primary	W	Primary Structural Type
		W Plan Irregularity Secondary	
		N Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Harris Elementary School

Eugene SD 4J

Lane\_sch09C

Building Type School	County Lane	
Street 1150 E 29th Ave		
City Eugene	State OR	Zip 97403
Latitude 44.02528	Longitude 123.0764	
Tracking Code RVS in 2006	Inspection Date 1/29/2007	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Harris Elementary School

## Final RVS Score

Final Type	Final Score
W2	1.3

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Harris Elementary School

Lane\_sch09C

Enrollment 215	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1950
Total Area (square ft) 40613	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Torsion: Eccentric Stiffness		Building On Hill or Sloped Site	
None		None	
Falling Hazards		Poor Conditions	
Other: Ornamental Hazard Over Exit		None	
None		None	
None		None	
			
NW Vertical Irregularity Secondary		W Plan Irregularity Secondary	
		W Primary Structural Type	
		S Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries