

# Thomas Jefferson Middle School

Eugene SD 4J

Lane\_sch11A

Building Type	County	
School	Lane	
Street		
1650 W 22nd Ave		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.03539	123.11528	
Tracking Code	Inspection Date	
SER & RVS2006	8/10/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	-0.4	0	0	3.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Thomas Jefferson Middle School

## Final RVS Score

Final Type	Final Score
W2	3.4

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Thomas Jefferson Middle School

Lane\_sch11A

Enrollment 266	Year Built (Field Verified) 1956	Year Built (Alt. Source) 1956	Est. Decade Built 1970
Total Area (square ft) 80190	Number of Stories 1	Basement No	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries