

John F Kennedy Middle School

Eugene SD 4J

Lane_sch13A

Building Type	County	
School	Lane	
Street		
2200 Bailey Hill Rd		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.03574	123.15515	
Tracking Code	Inspection Date	
SER & RVS2006	7/25/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S5	2	0	0	0	0	0	0	0	2
Secondary	RM1	2.8	0	0	0	0	0	0	0	2.8
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy Middle School

Final RVS Score

Final Type	Final Score
S5	2

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Lane_sch13A

Enrollment 487	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built 1970
Total Area (square ft) 80532	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W	Secondary Structural Type	S	Primary Structural Type



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Eugene SD 4J

Lane_sch13B

Building Type	County	
School	Lane	
Street		
2200 Bailey Hill Rd		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.03641	123.15553	
Tracking Code	Inspection Date	
SER & RVS2006	7/25/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C3	1.6	0	-0.5	0	0	0	0	0	1.1
Secondary	RM1	2.8	0	-0.5	0	0	0	0	0	2.3
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy Middle School

Final RVS Score

Final Type	Final Score
C3	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Lane_sch13B

Enrollment 487	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built 1970
Total Area (square ft) 80532	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes Steps in Elevation View: Very Irregular Changes (Adjacent Building/Ent) None	
Falling Hazards None None None		Poor Conditions None None None	
			
<p>E Plan Irregularity Primary Building B is on the right side. This shows the connection between building C and B. This picture also shows the vertical irregularity between building C and B.</p>		<p>NE General Site</p>	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Eugene SD 4J

Lane_sch13C

Building Type	County	
School	Lane	
Street		
2200 Bailey Hill Rd		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.03615	123.15545	
Tracking Code	Inspection Date	
SER & RVS2006	7/25/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy Middle School

Final RVS Score

Final Type	Final Score
RM1	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Lane_sch13C

Enrollment 487	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built 1970
Total Area (square ft) 80532	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Building On Hill or Sloped Site Steps in Elevation View: Single Change None	
Falling Hazards None None None		Poor Conditions None None None	
			
E Vertical Irregularity Primary		W General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Eugene SD 4J

Lane_sch13D

Building Type	County	
School	Lane	
Street		
2200 Bailey Hill Rd		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.03588	123.1559	
Tracking Code	Inspection Date	
SER & RVS2006	7/25/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy Middle School

Final RVS Score

Final Type	Final Score
RM1	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Lane_sch13D

Enrollment 487	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built 1970
Total Area (square ft) 80532	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
 W Plan Irregularity Primary			

John F Kennedy Middle School

Eugene SD 4J

Lane_sch13E

Building Type	County	
School	Lane	
Street		
2200 Bailey Hill Rd		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.03638	123.15431	
Tracking Code	Inspection Date	
SER & RVS2006	7/25/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy Middle School

Final RVS Score

Final Type	Final Score
RM1	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Lane_sch13E

Enrollment 487	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built 1970
Total Area (square ft) 80532	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
 NE Plan Irregularity Primary			

John F Kennedy Middle School

Eugene SD 4J

Lane_sch13F

Building Type	County	
School	Lane	
Street		
2200 Bailey Hill Rd		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.036	123.15475	
Tracking Code	Inspection Date	
SER & RVS2006	7/25/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy Middle School

Final RVS Score

Final Type	Final Score
RM1	2.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Lane_sch13F

Enrollment 487	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built 1970
Total Area (square ft) 80532	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 W General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

John F Kennedy Middle School

Eugene SD 4J

Lane_sch13G

Building Type	County	
School	Lane	
Street		
2200 Bailey Hill Rd		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.03599	123.15415	
Tracking Code	Inspection Date	
SER & RVS2006	7/25/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	0	0	0	0	0	0	1.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John F Kennedy Middle School

Final RVS Score

Final Type	Final Score
RM1	1.8

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

John F Kennedy Middle School

Lane_sch13G

Enrollment 487	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built 1970
Total Area (square ft) 80532	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Building On Hill or Sloped Site Steps in Elevation View: Very Irregular Changes (Adjacent Building/Ent) None	
Falling Hazards None None None		Poor Conditions None None None	
 E Vertical Irregularity Secondary			