

# McCornack Elementary School

Eugene SD 4J

Lane\_sch15A

Building Type	County
School	Lane
Street	
1968 Brittany Dr	
City	State Zip
Eugene	OR 97405
Latitude	Longitude
44.03799	123.14408
Tracking Code	Inspection Date
Structural Engineering Report 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

McCornack Elementary School

### Final RVS Score

Final Type	Final Score
RM1	1.3

### FEMA-154 Collapse Potential

Moderate (>1%)

No  
Planview  
Available



OregonGeology

# McCornack Elementary School

Lane\_sch15A

Enrollment 419	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1967	Est. Decade Built
Total Area (square ft) 49133	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	