

# River Road Elementary School

Eugene SD 4J

Lane\_sch18A

Building Type		County	
School		Lane	
Street			
120 W Hilliard Ln			
City	State	Zip	
Eugene	OR	97404	
Latitude		Longitude	
44.07866		123.12358	
Tracking Code		Inspection Date	
Structural Engineering Report		9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

River Road Elementary School

## Final RVS Score

Final Type

Final Score

W2

1.3

FEMA-154 Collapse Potential

Moderate (>1%)

# No Planview Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
314		1953	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
50381	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions