

Theodore Roosevelt Middle School

Eugene SD 4J

Lane_sch19A

Building Type	County
School	Lane
Street	
680 E 24th Ave	
City	State Zip
Eugene	OR 97405
Latitude	Longitude
44.0328	123.08274
Tracking Code	Inspection Date
SER & RVS2006	7/20/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Theodore Roosevelt Middle School

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Theodore Roosevelt Middle School

Lane_sch19A

Enrollment 672	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 105770	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
Reentrant Corners: Other (Adjacent Build/Entity)		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N Vertical Irregularity Secondary		SW Plan Irregularity Primary	
		S Plan Irregularity Primary	
			
S Vertical Irregularity Primary		E Vertical Irregularity Primary	
			
		NE Other braced parapets	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Theodore Roosevelt Middle School

Eugene SD 4J

Lane_sch19B

Building Type	County
School	Lane
Street	
680 E 24th Ave	
City	State Zip
Eugene	OR 97405
Latitude	Longitude
44.03312	123.08329
Tracking Code	Inspection Date
SER & RVS2006	7/20/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	0	0	3.7
Secondary	S3	3.2	0	-0.5	0	0	0	0	0	2.7
Tertiary		0	0	0	0	0	0	0	0	0

Theodore Roosevelt Middle School

Final RVS Score

Final Type	Final Score
S3	2.7

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Theodore Roosevelt Middle School

Lane_sch19B


Enrollment 672	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1980
Total Area (square ft) 105770	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	

Theodore Roosevelt Middle School

Eugene SD 4J

Lane_sch19C

Building Type	County	
School	Lane	
Street		
680 E 24th Ave		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.03271	123.08343	
Tracking Code	Inspection Date	
SER & RVS2006	7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	0	0	0	0	0	0	1.8
Secondary	RM1	2.8	-1	0	0	0	0	0	0	1.8
Tertiary		0	0	0	0	0	0	0	0	0

Theodore Roosevelt Middle School

Final RVS Score

Final Type	Final Score
W2	1.8

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Theodore Roosevelt Middle School

Lane_sch19C

Enrollment 672	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1970
Total Area (square ft) 105770	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
Reentrant Corners: Other (Adjacent Build/Entity)		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
None		Open cracks in structural members	
None		None	
None		None	
			
S	Poor Condition	S	Poor Condition
			
S General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries