

Spring Creek Elementary School

Eugene SD 4J

Lane_sch21A

Building Type	County
School	Lane
Street	
560 Irvington Dr	
City	State Zip
Eugene	OR 97404
Latitude	Longitude
44.11478	123.14419
Tracking Code	Inspection Date
SER & RVS2006	7/20/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	0	0	0	3.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Spring Creek Elementary School

Final RVS Score

Final Type	Final Score
W2	3.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Spring Creek Elementary School

Lane_sch21A

Enrollment 421	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built 1960
Total Area (square ft) 37569	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SW General Site		E Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Spring Creek Elementary School

Eugene SD 4J

Lane_sch21B

Building Type	County	
School	Lane	
Street		
560 Irvington Dr		
City	State	Zip
Eugene	OR	97404
Latitude	Longitude	
44.11458	123.14484	
Tracking Code	Inspection Date	
SER & RVS2006	7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	0	0	2.3
Secondary	W2	3.8	0	-0.5	0	0	0	0	0	3.3
Tertiary		0	0	0	0	0	0	0	0	0

Spring Creek Elementary School

Final RVS Score

Final Type	Final Score
RM1	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Spring Creek Elementary School

Lane_sch21B

Enrollment 421	Year Built (Field Verified) 1964	Year Built (Alt. Source) 1964	Est. Decade Built 1960
Total Area (square ft) 37569	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	