

Centennial Elementary School

Springfield SD 19

Lane_sch29A

Building Type	County	
School	Lane	
Street		
1315 Aspen St		
City	State	Zip
Springfield	OR	97477
Latitude	Longitude	
44.0577	123.04148	
Tracking Code	Inspection Date	
Previous FEMA-154 Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Centennial Elementary School

Final RVS Score

Final Type

Final Score

RM1

2.8

FEMA-154 Collapse Potential

Low (<1%)

No Planview Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
427		1963	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
64868	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions