

Springfield Middle School

Springfield SD 19

Lane_sch38A

Building Type	County
School	Lane
Street	
1084 G St	
City	State Zip
Springfield	OR 97477
Latitude	Longitude
44.0527	123.01075
Tracking Code	Inspection Date
Previous FEMA-154 Report	8/18/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8		-0.5						
Secondary										
Tertiary		0	0	0	0	0	0	0	0	0

Springfield Middle School

Final RVS Score

Final Type	Final Score
W2	0.3

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Springfield Middle School

Lane_sch38A

Enrollment 293	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1930
Total Area (square ft)	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Building On Hill or Sloped Site None None	
Falling Hazards None None None		Poor Conditions Cracks None None	