


# Thurston Elementary School

Springfield SD 19

Lane\_sch39A

Building Type School	County Lane	
Street 7345 Thurston Rd		
City Springfield	State OR	Zip 97478
Latitude 44.05143	Longitude 122.89487	
Tracking Code Previous FEMA-154 Report	Inspection Date 9/15/2006	



Seismicity Zone: Moderate											Thurston Elementary School	
FEMA 154 Rapid Visual Screening Score Card											Final RVS Score	
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score	Final Type	Final Score
Primary	W2	4.8	0	0	0	0	0	0	0	4.8	W2	4.8
Secondary		0	0	0	0	0	0	0	0	0		
Tertiary		0	0	0	0	0	0	0	0	0		
											FEMA-154 Collapse Potential	
											Low (<1%)	

# No Planview Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
462		1950	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
43674	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions