

Building Type	County	
School	Lane	
Street		
6300 Thurston Rd		
City	State	Zip
Springfield	OR	97478
Latitude	Longitude	
44.05452	122.91649	
Tracking Code	Inspection Date	
Previous FEMA-154 Report	9/15/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	0	0	0	0	4.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Thurston Middle School

Final RVS Score

Final Type	Final Score
W2	4.8

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Thurston Middle School

Lane_sch40A

Enrollment 542	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built
Total Area (square ft) 72212	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	