

Building Type	County	
School	Lane	
Street		
875 7th St		
City	State	Zip
Springfield	OR	97477
Latitude	Longitude	
44.05359	123.01574	
Tracking Code	Inspection Date	
Previous FEMA-154 Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	2.5	0	0	0	0	0	0	0	2.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Springfield High School

Final RVS Score

Final Type	Final Score
C1	2.5

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



Oregon Geology

Springfield High School

Lane_sch42A

Enrollment 1577	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1968	Est. Decade Built
Total Area (square ft) 268866	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	