

Building Type	County	
School	Lane	
Street		
333 58th St		
City	State	Zip
Springfield	OR	97478
Latitude	Longitude	
44.04921	122.92477	
Tracking Code	Inspection Date	
Previous FEMA-154 Report	9/15/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	0	0	0	3.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Thurston High School

Final RVS Score

Final Type	Final Score
RM1	3.6

FEMA-154 Collapse Potential

Low (&lt;1%)

No  
Planview  
Available



Oregon Geology

# Thurston High School

Lane\_sch43A

Enrollment 1514	Year Built (Field Verified) 1959	Year Built (Alt. Source) 1959	Est. Decade Built
Total Area (square ft) 290210	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	