

Bohemia Elementary School

Lane_sch50A

South Lane SD 45J3

Building Type		County	
School		Lane	
Street			
721 S R St			
City		State	Zip
Cottage Grove		OR	97424
Latitude		Longitude	
43.79304		123.07672	
Tracking Code		Inspection Date	
RVS in 2006		7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Bohemia Elementary School

Final RVS Score

Final Type

Final Score

W2

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
469		1976	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
53411	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Large Diaphragm or Central Opening	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



E Plan Irregularity Primary



E Plan Irregularity Primary
minor opening in the roof diaphragm

Bohemia Elementary School

South Lane SD 45J3

Lane_sch50B

Building Type		County	
School		Lane	
Street			
721 S R St			
City	State	Zip	
Cottage Grove	OR	97424	
Latitude		Longitude	
43.79251		123.07672	
Tracking Code		Inspection Date	
RVS in 2006		7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	0	0	0	-0.4	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Bohemia Elementary School

Final RVS Score

Final Type

Final Score

RM1

1.4

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
469		1976	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
53411	1	No	No

Plan Irregularities	Vertical Irregularities
None	Steps in Elevation View: Single Change
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



W Primary Structural Type