

Building Type		County	
School		Lane	
Street			
1525 Echo Hollow Rd			
City	State	Zip	
Eugene	OR	97402	
Latitude	Longitude		
44.0788	123.16639		
Tracking Code	Inspection Date		
Structural Engineering Report	9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Cascade Middle School

Final RVS Score

Final Type

Final Score

RM1

1.3

FEMA-154 Collapse Potential

Moderate (>1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
393		1955	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
86700	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions