

# Clear Lake Elementary School

Bethel SD 52

Lane\_sch55A

Building Type	County	
School	Lane	
Street		
4646 Barger Ave		
City	State	Zip
Eugene	OR	97402
Latitude	Longitude	
44.08321	123.17499	
Tracking Code	Inspection Date	
SER & RVS2006	7/27/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	-0.4	0	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clear Lake Elementary School

## Final RVS Score

Final Type	Final Score
W2	2.9

## FEMA-154 Collapse Potential

Low (<1%)




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Clear Lake Elementary School

Lane\_sch55A

Enrollment 380	Year Built (Field Verified) 1977	Year Built (Alt. Source) 1970	Est. Decade Built 1970
Total Area (square ft) 51911	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Building On Hill or Sloped Site	
Non-Parallel System		Steps in Elevation View: Single Change	
None		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Vertical Irregularity Tertiary		SW Vertical Irregularity Primary Minor sloped site.	
		SW Plan Irregularity Secondary	
			

# Clear Lake Elementary School

Bethel SD 52

Lane\_sch55B

Building Type	County
School	Lane
Street	
4646 Barger Ave	
City	State Zip
Eugene	OR 97402
Latitude	Longitude
44.08292	123.17494
Tracking Code	Inspection Date
SER & RVS2006	7/27/2006



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clear Lake Elementary School

## Final RVS Score

Final Type	Final Score
RM1	1.3

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Clear Lake Elementary School

Lane\_sch55B

Enrollment 380	Year Built (Field Verified) 1977	Year Built (Alt. Source) 1970	Est. Decade Built 1970
Total Area (square ft) 51911	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Non-Parallel System None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
S Vertical Irregularity Primary Due to adjacent building, building A is in the right and building B is on the left.		E Primary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries