

Fairfield Elementary School

Bethel SD 52

Lane_sch57A

Building Type	County
School	Lane
Street	
3455 Royal Ave	
City	State Zip
Eugene	OR 97402
Latitude	Longitude
44.07074	123.15006
Tracking Code	Inspection Date
Structural Engineering Report 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Fairfield Elementary School

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Fairfield Elementary School

Lane_sch57A

Enrollment 390	Year Built (Field Verified) 1952	Year Built (Alt. Source) 1952	Est. Decade Built
Total Area (square ft) 50570	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	