

# Oaklea Middle School

Junction City SD 69

Lane\_sch63A

|               |  |                 |       |
|---------------|--|-----------------|-------|
| Building Type |  | County          |       |
| School        |  | Lane            |       |
| Street        |  |                 |       |
| 1515 Rose St. |  |                 |       |
| City          |  | State           | Zip   |
| Junction City |  | OR              | 97448 |
| Latitude      |  | Longitude       |       |
| 44.22655      |  | 123.21501       |       |
| Tracking Code |  | Inspection Date |       |
| RVS in 2006   |  | 7/20/2006       |       |



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

|           | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary   | RM1  | 2.8         | -1         | -0.5       | 0        | 0          | 0      | -0.6   | 0      | 0.7       |
| Secondary | W2   | 3.8         | -2         | -0.5       | 0        | 0          | 0      | -0.8   | 0      | 0.5       |
| Tertiary  |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |

Oaklea Middle School

## Final RVS Score

Final Type

Final Score

W2

0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

|                        |                             |                          |                    |
|------------------------|-----------------------------|--------------------------|--------------------|
| Enrollment             | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built  |
| 514                    |                             | 1976                     | 1970               |
| Total Area (square ft) | Number of Stories           | Basement                 | Pounding Potential |
| 84700                  | 1                           | No                       | No                 |

|  |   |
|--|---|
| Plan Irregularities                            | Vertical Irregularities                 |
| Reentrant Corners: Other                       | Steps in Elevation View: 2 to 3 Changes |
| Out of Plane Lateral-Force-Resistance Elements | None                                    |
| None   | None                                    |

|                 |                 |
|-----------------|-----------------|
| Falling Hazards | Poor Conditions |
| None            | None            |
| None            | None            |
| None            | None            |

