

Oakridge Elementary School

Oakridge SD 76

Lane_sch65A

Building Type		County	
School		Lane	
Street			
48119 E 1st St			
City		State	Zip
Oakridge		OR	97463
Latitude		Longitude	
43.74844		122.46509	
Tracking Code		Inspection Date	
RVS in 2006		7/27/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Tertiary		0	0	0	0	0	0	0	0	0

Oakridge Elementary School

Final RVS Score

Final Type

Final Score

RM1

0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
270		1948	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
48960	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NE Plan Irregularity Primary

S General Site

S General Site

Oakridge Elementary School

Oakridge SD 76

Lane_sch65B

Building Type		County	
School		Lane	
Street			
48199 E 1st st			
City	State	Zip	
Oakridge	OR	97463	
Latitude		Longitude	
43.74884		122.46505	
Tracking Code		Inspection Date	
RVS in 2006		7/27/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	-0.8	0	0	3.5
Secondary	RM1	3.6	0	-0.5	0	0	-0.8	0	0	2.3
Tertiary		0	0	0	0	0	0	0	0	0

Oakridge Elementary School

Final RVS Score

Final Type

Final Score

RM1

2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
270		1948	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
48960	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners:T shaped (Adjacent Build/Entity)	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
Other: Brick Veneer	None