

Siuslaw High School

Siuslaw SD 97J

Lane_sch70A

| | |
|---------------|-----------------|
| Building Type | County |
| School | Lane |
| Street | |
| 2975 Oak St | |
| City | State Zip |
| Florence | OR 97439 |
| Latitude | Longitude |
| 43.99207 | 124.10588 |
| Tracking Code | Inspection Date |
| RVS in 2006 | 8/3/2006 |



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | PC1 | 2.6 | 0 | -0.5 | 0 | 0 | -0.4 | 0 | 0 | 1.7 |
| Secondary | W2 | 3.8 | -2 | -0.5 | 0 | 0 | -0.4 | 0 | 0 | 0.9 |
| Tertiary | C2 | 2.8 | -1 | -0.5 | 0 | 0 | -0.4 | 0 | 0 | 0.9 |

Siuslaw High School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| W2 | 0.9 |

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Siuslaw High School

Lane_sch70A

| | | | |
|---|-------------------------------------|---|---------------------------|
| Enrollment 572 | Year Built (Field Verified) 1970 | Year Built (Alt. Source) 1970 | Est. Decade Built 1960 |
| Total Area (square ft) 109747 | Number of Stories 2 | Basement | Pounding Potential No |
| Plan Irregularities Reentrant Corners: Other Reentrant Corners: L Shaped (Adjacent Build/Entity) None | | Vertical Irregularities Steps in Elevation View: Very Irregular Changes None None | |
| Falling Hazards None None None | | Poor Conditions None None None | |
|  | |  | |
| E Plan Irregularity Primary | | NE Vertical Irregularity Primary | |
|  | |  | |
| N General Site | | W Tertiary Structural Type | |
|  | |  | |
| S Secondary Structural Type | | SE Plan Irregularity Primary | |
|  | |  | |
| E Primary Structural Type | | | |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Siuslaw High School

Siuslaw SD 97J

Lane_sch70B

| | |
|---------------|-----------------|
| Building Type | County |
| School | Lane |
| Street | |
| 2975 Oak St | |
| City | State Zip |
| Florence | OR 97439 |
| Latitude | Longitude |
| 43.99175 | 124.10682 |
| Tracking Code | Inspection Date |
| RVS in 2006 | 8/3/2006 |



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | PC1 | 2.6 | 0 | -0.5 | 0 | 0 | -0.4 | 0 | 0 | 1.7 |
| Secondary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Siuslaw High School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| PC1 | 1.7 |

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Siuslaw High School

Lane_sch70B

| | | | |
|---|-------------------------------------|---|---------------------------|
| Enrollment 572 | Year Built (Field Verified) 1970 | Year Built (Alt. Source) 1970 | Est. Decade Built 1980 |
| Total Area (square ft) 109747 | Number of Stories 1 | Basement | Pounding Potential No |
| Plan Irregularities Reentrant Corners: L Shaped None None | | Vertical Irregularities None None None | |
| Falling Hazards None None None | | Poor Conditions None None None | |
|  S Plan Irregularity Primary | | | |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Siuslaw High School

Siuslaw SD 97J

Lane_sch70C

| | | |
|------------------------------|-----------------------------|--------------|
| Building Type School | County Lane | |
| Street 2975 Oak St | | |
| City Florence | State OR | Zip 97439 |
| Latitude 43.99264 | Longitude 124.10644 | |
| Tracking Code RVS in 2006 | Inspection Date 8/3/2006 | |



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | RM1 | 2.8 | 0 | -0.5 | 0 | 0 | -0.4 | 0 | 0 | 1.9 |
| Secondary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Siuslaw High School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| RM1 | 1.9 |

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Siuslaw High School

Lane_sch70C

| | | | |
|--|-------------------------------------|---|--|
| Enrollment 572 | Year Built (Field Verified) 1970 | Year Built (Alt. Source) 1970 | Est. Decade Built 1970 |
| Total Area (square ft) 109747 | Number of Stories 1 | Basement | Pounding Potential No |
| Plan Irregularities Reentrant Corners: L Shaped None None | | Vertical Irregularities None None None | |
| Falling Hazards None None None | | Poor Conditions None None None | |
|  | |  |  |
| NE General Site | N Primary Structural Type | NW General Site | |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries