

Fox Hollow French Immersion School

Lane_sch71A

Eugene SD 4J

Building Type		County	
School		Lane	
Street			
5055 Mahalo			
City	State	Zip	
Eugene	OR	97405	
Latitude		Longitude	
43.99914		123.08081	
Tracking Code		Inspection Date	
Structural Engineering Report		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Fox Hollow French Immersion School

Final RVS Score

Final Type

Final Score

RM1

1.3

FEMA-154 Collapse Potential

Moderate (>1%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
301		1967	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
27872	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions

