

Building Type	County	
School	Lane	
Street		
425 10th St		
City	State	Zip
Springfield	OR	97477
Latitude	Longitude	
44.04919	123.01199	
Tracking Code	Inspection Date	
Previous FEMA-154 Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	-1	0	-0.4	0	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Brattain Elementary School

Final RVS Score

Final Type	Final Score
W2	2.4

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



Brattain Elementary School

Lane_sch85A

Enrollment 254	Year Built (Field Verified) 1925	Year Built (Alt. Source) 1925	Est. Decade Built
Total Area (square ft) 27746	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	