


Creslane Elementary School

Creswell SD 40

Lane_sch90A

Building Type	County
School	Lane
Street	
996 W A Ave	
City	State Zip
Creswell	OR 97426
Latitude	Longitude
43.92036	123.02926
Tracking Code	Inspection Date
RVS in 2006	1/29/2007



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Creslane Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Creslane Elementary School

Lane_sch90A

Enrollment 561	Year Built (Field Verified) 1948	Year Built (Alt. Source) 1948	Est. Decade Built 1950
Total Area (square ft) 35370	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) Steps in Elevation View: 2 to 3 Changes None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions None None None	
 SE Falling Hazard		 SE Primary Structural Type	 SW Plan Irregularity Primary b on left



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Creslane Elementary School

Creswell SD 40

Lane_sch90B

Building Type	County
School	Lane
Street	
996 W A Ave	
City	State Zip
Creswell	OR 97426
Latitude	Longitude
43.92069	123.02908
Tracking Code	Inspection Date
RVS in 2006	1/29/2007



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	0	-0.8	0	2.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Creslane Elementary School

Final RVS Score

Final Type	Final Score
W2	2.5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Creslane Elementary School

Lane_sch90B

Enrollment 561	Year Built (Field Verified) 1948	Year Built (Alt. Source) 1948	Est. Decade Built 1950
Total Area (square ft) 35370	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) Lateral-Force-Resistance in One Direction Only None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Elevation View		 N Primary Structural Type	
		 N Plan Irregularity Secondary hall transom windows	
 N Plan Irregularity Primary		 NW Plan Irregularity Secondary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Creslane Elementary School

Creswell SD 40

Lane_sch90C

Building Type	County
School	Lane
Street	
996 W A Ave	
City	State Zip
Creswell	OR 97426
Latitude	Longitude
43.92054	123.02842
Tracking Code	Inspection Date
RVS in 2006	1/29/2007



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	-0.8	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Creslane Elementary School

Final RVS Score

Final Type	Final Score
W2	2.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Creslane Elementary School

Lane_sch90C

Enrollment 561	Year Built (Field Verified) 1948	Year Built (Alt. Source) 1948	Est. Decade Built 1980
Total Area (square ft) 35370	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N Plan Irregularity Secondary		N Plan Irregularity Primary	
		N Primary Structural Type	
			
E Elevation View		tectum roof	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries