

# Walterville Elementary School

Springfield SD 19

Lane\_sch92A

Building Type School	County Lane	
Street 40589 McKenzie Hwy		
City Springfield	State OR	Zip 97478
Latitude 44.07867	Longitude 122.76199	
Tracking Code Previous FEMA-154 Report	Inspection Date 7/27/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Walterville Elementary School

### Final RVS Score

Final Type	Final Score
RM1	-0.1

### FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

# Walterville Elementary School

Lane\_sch92A

Enrollment 171	Year Built (Field Verified) 1952	Year Built (Alt. Source) 1952	Est. Decade Built 1950
Total Area (square ft) 22668	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		None	
None		None	
None		None	
			
E	General Site	N	General Site
		N	
		Field Verified Year Built	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Walterville Elementary School

Springfield SD 19

Lane\_sch92B

Building Type School	County Lane	
Street 40589 McKenzie Hwy		
City Springfield	State OR	Zip 97478
Latitude 44.07844	Longitude 122.76217	
Tracking Code Previous FEMA-154 Report	Inspection Date 7/27/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Walterville Elementary School

## Final RVS Score

Final Type	Final Score
RM1	-0.1

## FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

# Walterville Elementary School

Lane\_sch92B

Enrollment 171	Year Built (Field Verified) 1952	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 22668	Number of Stories 1	Basement	Pounding Potential No
<b>Plan Irregularities</b> Reentrant Corners: Other Out of Plane Lateral-Force-Resistance Elements None		<b>Vertical Irregularities</b> Steps in Elevation View: 2 to 3 Changes None None	
<b>Falling Hazards</b> None None None		<b>Poor Conditions</b> None None None	
			
W Vertical Irregularity Primary		W Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
 Oregon Department of Geology and Mineral Industries