

Coburg Elementary School

Eugene SD 4J

Lane_sch96A

Building Type School	County Lane	
Street 91274 N Coburg Rd		
City Eugene	State OR	Zip 97408
Latitude 44.14248	Longitude 123.07239	
Tracking Code SER & RVS2006	Inspection Date 7/27/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Tertiary		0	0	0	0	0	0	0	0	0

Coburg Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Coburg Elementary School

Lane_sch96A

Enrollment 150	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 27537	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: U shaped None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	

Coburg Elementary School

Eugene SD 4J

Lane_sch96B

Building Type	County	
School	Lane	
Street		
91274 N Coburg Rd		
City	State	Zip
Eugene	OR	97408
Latitude	Longitude	
44.14316	123.07234	
Tracking Code	Inspection Date	
SER & RVS2006	7/27/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Coburg Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Coburg Elementary School

Lane_sch96B

Enrollment 150	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1970
Total Area (square ft) 27537	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W Vertical Irregularity Primary out of plane lateral system also			

Coburg Elementary School

Eugene SD 4J

Lane_sch96C

Building Type School	County Lane	
Street 91274 N Coburg Rd		
City Eugene	State OR	Zip 97408
Latitude 44.14237	Longitude 123.07303	
Tracking Code SER & RVS2006	Inspection Date 7/27/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Coburg Elementary School

Final RVS Score

Final Type	Final Score
RM1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Coburg Elementary School

Lane_sch96C

Enrollment 150	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1960
Total Area (square ft) 27537	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Torsion: Eccentric Stiffness None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries