

Lincoln County Communications Agency

Lincoln County

Linc_eoc01A

Building Type EOC-Public Safety Answering P	County Lincoln	
Street 815 SW Lee St		
City Newport	State OR	Zip 97365
Latitude 44.63376	Longitude 124.05505	
Tracking Code New Building	Inspection Date 8/16/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lincoln County Communications Agency

Final RVS Score

Final Type W1	Final Score 1.4
------------------	--------------------

FEMA-154 Collapse Potential

Moderate (>1%)



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Lincoln County Communications Agency

Linc_eoc01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1997	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
24942	4	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: Very Irregular Changes	
None		Building On Hill or Sloped Site	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N	Vertical Irregularity Primary	SE	Plan Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries