

City of Toledo Fire Department

City of Toledo

Linc_fir06A

Building Type Fire - City	County Lincoln	
Street 496 E Hwy 20		
City Toledo	State OR	Zip 97391
Latitude 44.62399	Longitude 123.93185	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

City of Toledo Fire Department

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

City of Toledo Fire Department

Linc_fir06A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Non-Parallel System		None	
None		None	
Falling Hazards		Poor Conditions	
None		Cracks	
None		None	
None		None	
			
NW General Site		NW Poor Condition cracks	
		NE Plan Irregularity Secondary	
			
SE General Site		SE Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries