

# Seal Rock RFPD

Linc\_fir09A

## Seal Rock RFPD

Building Type Fire - RFPD	County Lincoln	
Street 10333 NW Rand St		
City Seal Rock	State OR	Zip 97376
Latitude 44.49926	Longitude 124.08131	
Tracking Code RVS in 2006	Inspection Date 8/12/2006	



Seismicity Zone: Very High

### FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Seal Rock RFPD

### Final RVS Score

Final Type	Final Score
W1	4.4

### FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Out of Plane Lateral-Force-Resistance Elements		None	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E Plan Irregularity Primary			

