

# Samaritan Pacific Communities Hospital - Newport

Linc\_hos01A

Samaritan Health Services NFP

Building Type		County	
Hospital		Lincoln	
Street			
930 Sw Abbey St			
City	State	Zip	
Newport	OR	97365	
Latitude		Longitude	
44.62935		124.0596	
Tracking Code		Inspection Date	
RVS in 2006		9/15/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	0	0	0	0	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Samaritan Pacific Communities Hospital - Newport

## Final RVS Score

Final Type

Final Score

C2

2.8

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1952	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions