

Lincoln County Sheriff's Office

Lincoln County

Linc_pol02A

Building Type Police - County	County Lincoln	
Street 225 W Olive St		
City Newport	State OR	Zip 97365
Latitude 44.63621	Longitude 124.05486	
Tracking Code RVS in 2006	Inspection Date 8/16/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lincoln County Sheriff's Office

Final RVS Score

Final Type	Final Score
C2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Lincoln County Sheriff's Office

Linc_pol02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1955	1955	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	3	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: 2 to 3 Changes	
None		Building On Hill or Sloped Site	
None		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Falling Hazards		Poor Conditions	
Other: General		None	
Other: Light Cladding		None	
None		None	
			
W Primary Structural Type	SW Plan Irregularity Primary	SE General Site	
			
E Falling Hazard	N Falling Hazard	SW Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Lincoln County Sheriff's Office

Lincoln County

Linc_pol02B

Building Type Police - County	County Lincoln	
Street 225 W Olive St		
City Newport	State OR	Zip 97365
Latitude 44.63596	Longitude 124.05478	
Tracking Code RVS in 2006	Inspection Date 8/16/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	0	0	0	0	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lincoln County Sheriff's Office

Final RVS Score

Final Type	Final Score
C2	2.8

FEMA-154 Collapse Potential

Low (<1%)



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Lincoln County Sheriff's Office

Linc_pol02B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1955	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	3	No	No
Plan Irregularities		Vertical Irregularities	
None		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		Building On Hill or Sloped Site	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries