

Oceanlake Elementary School

Lincoln County SD

Linc_sch01A

Building Type		County	
School		Lincoln	
Street			
2420 NE 22nd St			
City	State	Zip	
Lincoln City	OR	97367	
Latitude		Longitude	
44.98087		124.00299	
Tracking Code		Inspection Date	
RVS in 2006		8/10/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Tertiary		0	0	0	0	0	0	0	0	0

Oceanlake Elementary School

Final RVS Score

Final Type

Final Score

W2

1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
454	1951	1951	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
32386	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Out of Plane Lateral-Force-Resistance Elements	None
None	None

Falling Hazards	Poor Conditions
Unreinforced Chimneys	None
None	None
None	None



N Vertical Irregularity Primary



N Falling Hazard reinforced?



NW Plan Irregularity Secondary



SE Plan Irregularity Primary



SE Primary Structural Type



SW Plan Irregularity Primary