

Taft Middle School

Lincoln County SD

Linc_sch04A

| | |
|---------------------|-----------------|
| Building Type | County |
| School | Lincoln |
| Street | |
| 4040 High School Dr | |
| City | State Zip |
| Lincoln City | OR 97367 |
| Latitude | Longitude |
| 44.93533 | 124.01726 |
| Tracking Code | Inspection Date |
| RVS in 2006 | 8/10/2006 |



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | RM1 | 2.8 | -1 | -0.5 | 0 | 0 | 0 | 0 | 0 | 1.3 |
| Secondary | W2 | 3.8 | -2 | -0.5 | 0 | 0 | 0 | 0 | 0 | 1.3 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Taft Middle School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| RM1 | 1.3 |

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Taft Middle School

Linc_sch04A

| | | | |
|---|-------------------------------------|--|---------------------------|
| Enrollment 269 | Year Built (Field Verified) 1951 | Year Built (Alt. Source) 1951 | Est. Decade Built 1950 |
| Total Area (square ft) 71595 | Number of Stories 2 | Basement | Pounding Potential No |
| Plan Irregularities | | Vertical Irregularities | |
| Out of Plane Lateral-Force-Resistance Elements None | | Steps in Elevation View: Very Irregular Changes Building On Hill or Sloped Site None | |
| Falling Hazards | | Poor Conditions | |
| Unreinforced Chimneys None None | | Cracks None None | |
|  | |  | |
| W | Vertical Irregularity Secondary | W | General Site |
|  | |  | |
| W | Poor Condition cracks | | |
|  | |  | |
| E | General Site | E | Primary Structural Type |
|  | |  | |
| S | General Site | | |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Taft Middle School

Lincoln County SD

Linc_sch04B

| | | |
|-------------------------------|------------------------------|--------------|
| Building Type School | County Lincoln | |
| Street 4040 High School Dr | | |
| City Lincoln City | State OR | Zip 97367 |
| Latitude 44.93467 | Longitude 124.01673 | |
| Tracking Code RVS in 2006 | Inspection Date 8/10/2006 | |



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | W1 | 4.4 | 0 | 0 | 0 | 2.4 | 0 | 0 | 0 | 6.8 |
| Secondary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Taft Middle School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| W1 | 6.8 |

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Taft Middle School

Linc_sch04B

| | | | |
|--|-------------------------------------|--|---------------------------|
| Enrollment 269 | Year Built (Field Verified) 1951 | Year Built (Alt. Source) 1951 | Est. Decade Built 1980 |
| Total Area (square ft) 71595 | Number of Stories 1 | Basement | Pounding Potential No |
| Plan Irregularities None None None | | Vertical Irregularities None None None | |
| Falling Hazards None None None | | Poor Conditions None None None | |
|  | |  | |
| E Primary Structural Type | W General Site | | |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries