

Toledo Middle School

Lincoln County SD

Linc_sch05A

Building Type		County	
School		Lincoln	
Street			
600 SE Sturdevant Rd			
City	State	Zip	
Toledo	OR	97391	
Latitude		Longitude	
44.61745		123.92034	
Tracking Code		Inspection Date	
RVS in 2006		8/12/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Toledo Middle School

Final RVS Score

Final Type

Final Score

RM1

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
249		1987	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
52671	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Very Irregular Changes
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NE Plan Irregularity Primary
steps in elevation also. The structure type is unclear for the upper level of this building.



SE Plan Irregularity Primary



SW Plan Irregularity Primary

