

# Newport Early Childhood Center

Lincoln County SD

Linc\_sch13A

Building Type	County
School	Lincoln
Street	
420 NE 12th St	
City	State Zip
Newport	OR 97365
Latitude	Longitude
44.64518	124.04795
Tracking Code	Inspection Date
RVS in 2006	8/11/2006



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary	RM1	2.8	0	0	0	0	0	0	0	2.8
Tertiary		0	0	0	0	0	0	0	0	0

Newport Early Childhood Center

## Final RVS Score

Final Type	Final Score
RM1	2.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Newport Early Childhood Center

Linc\_sch13A

Enrollment 115	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built 1970
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 E Primary Structural Type			