

Lincoln City Career Technical High School

Lincoln County SD

Linc_sch14A

Building Type	County	
School	Lincoln	
Street		
801 SW Hwy 101 Suite 104		
City	State	Zip
Lincoln City	OR	97367
Latitude	Longitude	
44.96094	124.01582	
Tracking Code	Inspection Date	
RVS in 2006	8/10/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM2	3.2	-1	-0.5	0	2.6	0	0	0	3.9
Secondary	C2	2.8	-1	-0.5	0	2.4	0	0	0	4.1
Tertiary	C1	2.9	-1.5	-0.5	0	0	0	0	0	0.9

Lincoln City Career Technical High School

Final RVS Score

Final Type	Final Score
C1	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Lincoln City Career Technical High School

Linc_sch14A

Enrollment 56	Year Built (Field Verified) 1993	Year Built (Alt. Source) 1993	Est. Decade Built 1990
Total Area (square ft) 25500	Number of Stories 4	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped Non-Parallel System None		Vertical Irregularities Steps in Elevation View: Single Change Soft Story Building On Hill or Sloped Site	
Falling Hazards None None None		Poor Conditions None None None	
			
NE Plan Irregularity Primary step in elevation also		E Primary Structural Type soft story also	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries