

Building Type		County	
School		Lincoln	
Street			
805 NE Reservoir Ln			
City	State	Zip	
Toledo	OR	97391	
Latitude	Longitude		
44.62574	123.93428		
Tracking Code	Inspection Date		
RVS in 2006	8/11/2006		



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Olalla Center for Children & Families

Final RVS Score

Final Type

Final Score

W1

1.4

FEMA-154 Collapse Potential

Moderate (>1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
10		1978	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
5580	3	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Single Change
None	Building On Hill or Sloped Site
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None

