

Sweet Home Fire And Ambulance #21

Linn_fir07A

City of Sweet Home

Building Type	County	
Fire - City	Linn	
Street		
1099 Long St		
City	State	Zip
Sweet Home	OR	97386
Latitude	Longitude	
44.39615	122.73096	
Tracking Code	Inspection Date	
New Building	7/7/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	1.6	0	-1.2	0	2.2
Secondary	S3	3.8	0	0	0	0	0	-1	0	2.8
Tertiary		0	0	0	0	0	0	0	0	0

Sweet Home Fire And Ambulance #21

Final RVS Score

Final Type	Final Score
W2	2.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sweet Home Fire And Ambulance #21

Linn_fir07A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built		
		1994	1990		
Total Area (square ft)	Number of Stories	Basement	Pounding Potential		
	1	No	No		
Plan Irregularities		Vertical Irregularities			
Reentrant Corners:Other (Adjacent Build/Entity)		Steps in Elevation View: Single Change			
None		Steps in Elevation View: Single Change (Adjacent Building/Entity)			
None		None			
Falling Hazards		Poor Conditions			
None		None			
None		None			
None		None			
					
S	Vertical Irregularity Primary	N	Plan Irregularity Primary vertical irregularity - adjacent bldg - single step in elevation	NE	General Site
					



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sweet Home Fire And Ambulance #21

Linn_fir07B

City of Sweet Home

Building Type	County	
Fire - City	Linn	
Street		
1099 Long St		
City	State	Zip
Sweet Home	OR	97386
Latitude	Longitude	
44.39621	122.7307	
Tracking Code	Inspection Date	
New Building	7/7/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	1.6	0	-0.6	0	6.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sweet Home Fire And Ambulance #21

Final RVS Score

Final Type	Final Score
W1	6.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sweet Home Fire And Ambulance #21

Linn_fir07B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1994	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries