

Mill City Fire Department

Mill City RFPD

Linn_fir13A

Building Type Fire - RFPD	County Linn	
Street 400 S 1st Ave		
City Mill City	State OR	Zip 97360
Latitude 44.75214	Longitude 122.47703	
Tracking Code RVS in 2006	Inspection Date 6/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mill City Fire Department

Final RVS Score

Final Type RM1	Final Score -0.1
-------------------	---------------------

FEMA-154 Collapse Potential

Very High (100%)



Mill City Fire Department

Linn_fir13A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1992	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:Other (Adjacent Build/Entity)		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE Vertical Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mill City Fire Department

Mill City RFPD

Linn_fir13B

Building Type Fire - RFPD	County Linn	
Street 400 S 1st Ave		
City Mill City	State OR	Zip 97360
Latitude 44.75198	Longitude 122.47709	
Tracking Code RVS in 2006	Inspection Date 6/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	-3.5	-0.5	0	1.6	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mill City Fire Department

Final RVS Score

Final Type	Final Score
W1	2.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mill City Fire Department

Linn_fir13B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1992	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:Other (Adjacent Build/Entity)		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S Vertical Irregularity Primary reentrant corner			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries