

Building Type		County	
Police - County		Linn	
Street			
274 Cedar St.			
City	State	Zip	
Mill City	OR	97360	
Latitude		Longitude	
44.75313		122.47824	
Tracking Code		Inspection Date	
RVS in 2006		6/28/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	0	0	-1.2	0	0.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Linn County Sheriff's Office

## Final RVS Score

Final Type

Final Score

W2

0.6

FEMA-154 Collapse Potential

High (&gt;10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities
None	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
Unreinforced Chimneys	None
None	None
None	None

