

Clover Ridge Elementary School

Greater Albany SD 8J

Linn_sch01A

Building Type	County
School	Linn
Street	
2953 Clover Ridge Rd NE	
City	State Zip
Albany	OR 97321
Latitude	Longitude
44.66855	123.03529
Tracking Code	Inspection Date
Hasenberg 02	9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	-1	0	0	-0.8	0	2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clover Ridge Elementary School

Final RVS Score

Final Type	Final Score
W2	2

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Clover Ridge Elementary School

Linn_sch01A

Enrollment 305	Year Built (Field Verified) 1915	Year Built (Alt. Source) 1915	Est. Decade Built
Total Area (square ft) 36750	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
			
Falling Hazards		Poor Conditions	
			
 S General Site			