

# Periwinkle Elementary School

Greater Albany SD 8J

Linn\_sch02A

Building Type	County	
School	Linn	
Street		
2196 21st Ave SE		
City	State	Zip
Albany	OR	97322
Latitude	Longitude	
44.62108	123.07818	
Tracking Code	Inspection Date	
Hasenberg 02	9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Periwinkle Elementary School

### Final RVS Score

Final Type	Final Score
W2	0.5

### FEMA-154 Collapse Potential

High (>10%)

No  
Planview  
Available



OregonGeology

# Periwinkle Elementary School

Linn\_sch02A

Enrollment 484	Year Built (Field Verified) 1977	Year Built (Alt. Source) 1977	Est. Decade Built 1970
Total Area (square ft) 38325	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements		Vertical Irregularities Steps in Elevation View: Single Change	
		None	
		None	
Falling Hazards None		Poor Conditions None	
None		None	
None		None	
			
S	General Site	S	General Site