

Memorial Middle School

Greater Albany SD 8J

Linn_sch07A

Building Type	County	
School	Linn	
Street		
1050 Queen Ave SW		
City	State	Zip
Albany	OR	97321
Latitude	Longitude	
44.62275	123.11512	
Tracking Code	Inspection Date	
Hasenberg 02	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	0	0	0	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Memorial Middle School

Final RVS Score

Final Type	Final Score
C2	2.2

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Memorial Middle School

Linn_sch07A

Enrollment 636	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built
Total Area (square ft) 100815	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site