

Hamilton Creek School

Lebanon Community SD 9

Linn_sch13A

Building Type	County	
School	Linn	
Street		
32135 Berlin Rd		
City	State	Zip
Lebanon	OR	97355
Latitude	Longitude	
44.51338	122.83565	
Tracking Code	Inspection Date	
RVS in 2006	7/7/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	1.6	0	0	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hamilton Creek School

Final RVS Score

Final Type	Final Score
W2	2.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hamilton Creek School

Linn_sch13A

Enrollment 368	Year Built (Field Verified) 1972	Year Built (Alt. Source) 1972	Est. Decade Built 1980
Total Area (square ft) 36688	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes Internal Discontinuous Diaphragm (large internal opening) Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Falling Hazards None None None		Poor Conditions None None None	
			
W General Site		SW Vertical Irregularity Primary	
		SW General Site gym is Linn_sch13B	
		N General Site	

Hamilton Creek School

Lebanon Community SD 9

Linn_sch13B

Building Type	County	
School	Linn	
Street		
32135 Berlin Rd		
City	State	Zip
Lebanon	OR	97355
Latitude	Longitude	
44.51366	122.83613	
Tracking Code	Inspection Date	
RVS in 2006	7/7/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	1.6	0	0	0	3.4
Secondary	S3	3.8	0	0	0	0	0	0	0	3.8
Tertiary		0	0	0	0	0	0	0	0	0

Hamilton Creek School

Final RVS Score

Final Type	Final Score
W2	3.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Hamilton Creek School

Linn_sch13B

Enrollment 368	Year Built (Field Verified) 1972	Year Built (Alt. Source) 1972	Est. Decade Built 1990
Total Area (square ft) 36688	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
NE General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries