

Sweet Home Junior High School

Linn_sch18A

Sweet Home SD 55

Building Type	County	
School	Linn	
Street		
880 22nd Ave		
City	State	Zip
Sweet Home	OR	97386
Latitude	Longitude	
44.39388	122.71924	
Tracking Code	Inspection Date	
RVS in 2006	7/7/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

Sweet Home Junior High School

Final RVS Score

Final Type Final Score

S1 0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sweet Home Junior High School

Linn_sch18A

Enrollment 394	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1960
Total Area (square ft) 53512	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: U shaped		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Reentrant Corners: Other		None	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
Falling Hazards None		Poor Conditions None	
None		None	
None		None	
			
S Primary Structural Type steel columns -- wood beams	N Plan Irregularity Primary		N General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sweet Home Junior High School

Sweet Home SD 55

Linn_sch18B

Building Type	County
School	Linn
Street	
880 22nd Ave	
City	State Zip
Sweet Home	OR 97386
Latitude	Longitude
44.39389	122.71992
Tracking Code	Inspection Date
RVS in 2006	7/7/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	S4	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Tertiary		0	0	0	0	0	0	0	0	0

Sweet Home Junior High School

Final RVS Score

Final Type	Final Score
C2	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sweet Home Junior High School

Linn_sch18B

Enrollment 394	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1960	Est. Decade Built 1960
Total Area (square ft) 53512	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	

Sweet Home Junior High School

Sweet Home SD 55

Linn_sch18C

Building Type	County
School	Linn
Street	
880 22nd Ave	
City	State Zip
Sweet Home	OR 97386
Latitude	Longitude
44.39336	122.71985
Tracking Code	Inspection Date
RVS in 2006	7/7/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	0	-0.2	0	0	5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sweet Home Junior High School

Final RVS Score

Final Type	Final Score
W1	5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sweet Home Junior High School

Linn_sch18C

Enrollment 394	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1970
Total Area (square ft) 53512	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sweet Home Junior High School

Sweet Home SD 55

Linn_sch18D

Building Type	County
School	Linn
Street	
880 22nd Ave	
City	State Zip
Sweet Home	OR 97386
Latitude	Longitude
44.3936	122.7201
Tracking Code	Inspection Date
RVS in 2006	7/7/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sweet Home Junior High School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Sweet Home Junior High School

Linn_sch18D

Enrollment 394	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1970
Total Area (square ft) 53512	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
			
E Plan Irregularity Primary			