

# Lebanon High School

Lebanon Community SD 9

Linn\_sch28A

Building Type	County
School	Linn
Street	
1700 S 5th St	
City	State Zip
Lebanon	OR 97355
Latitude	Longitude
44.52911	122.91369
Tracking Code	Inspection Date
RVS in 2006	1/30/2007



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Lebanon High School

### Final RVS Score

Final Type	Final Score
C2	-0.1

### FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

# Lebanon High School

Linn\_sch28A

Enrollment 1332	Year Built (Field Verified) 1957	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 170158	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes (Adjacent Building/Ent) None None	
Falling Hazards None None None		Poor Conditions None None None	
			SE Elevation View old gym a in ctr
SW Elevation View	SW Elevation View	SW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Lebanon High School

Lebanon Community SD 9

Linn\_sch28B

Building Type	County
School	Linn
Street	
1700 S 5th St	
City	State Zip
Lebanon	OR 97355
Latitude	Longitude
44.52991	122.91539
Tracking Code	Inspection Date
RVS in 2006	1/30/2007



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Lebanon High School

## Final RVS Score

Final Type	Final Score
RM1	-0.1

## FEMA-154 Collapse Potential

Very High (100%)



Linn\_sch28



OregonGeology

# Lebanon High School

Linn\_sch28B

Enrollment 1332	Year Built (Field Verified) 1957	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 170158	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	



SE Vertical Irregularity Primary



S Primary Structural Type




SW Plan Irregularity Secondary



W Elevation View



W Elevation View



W Primary Structural Type  
stl cols and cmu



NW Elevation View



N Primary Structural Type



NE Primary Structural Type



# OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries