

Building Type	County	
School	Linn	
Street		
830 24th Ave SE		
City	State	Zip
Albany	OR	97322
Latitude	Longitude	
44.61775	123.09281	
Tracking Code	Inspection Date	
Previous FEMA-154 Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5			-0.6			
Secondary	PC1	2.6		-0.5			-0.6			1.5
Tertiary										

Calapooia Middle School

Final RVS Score

Final Type	Final Score
C2	0.7

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Oregon Geology

Calapooia Middle School

Linn_sch38A

Enrollment 743	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built
Total Area (square ft) 96315	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



S General Site



S General Site



S General Site