

Harrisburg Middle School

Linn_sch40A

Harrisburg SD 7J

Building Type	County	
School	Linn	
Street		
201 S 6th St		
City	State	Zip
Harrisburg	OR	97446
Latitude	Longitude	
44.2715	123.1657	
Tracking Code	Inspection Date	
RVS in 2006	7/31/2006	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	0	-0.6	0	-0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Harrisburg Middle School

Final RVS Score

Final Type	Final Score
C2	-0.3

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Harrisburg Middle School

Linn_sch40A

Enrollment 189	Year Built (Field Verified) 1936	Year Built (Alt. Source) 1936	Est. Decade Built 1930
Total Area (square ft) 25493	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other None		Steps in Elevation View: Single Change Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions Cracks None None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Harrisburg Middle School

Harrisburg SD 7J

Linn_sch40B

Building Type School	County Linn	
Street 201 S 6th St		
City Harrisburg	State OR	Zip 97446
Latitude 44.27101	Longitude 123.16534	
Tracking Code RVS in 2006	Inspection Date 7/31/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Harrisburg Middle School

Final RVS Score

Final Type	Final Score
RM1	2.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Harrisburg Middle School

Linn_sch40B

Enrollment 189	Year Built (Field Verified) 1993	Year Built (Alt. Source) 1936	Est. Decade Built 1990
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
N General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Harrisburg Middle School

Harrisburg SD 7J

Linn_sch40C

Building Type School	County Linn	
Street 201 S 6th St		
City Harrisburg	State OR	Zip 97446
Latitude 44.27083	Longitude 123.1657	
Tracking Code RVS in 2006	Inspection Date 7/31/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary	C2	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Tertiary		0	0	0	0	0	0	0	0	0

Harrisburg Middle School

Final RVS Score

Final Type	Final Score
RM1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Harrisburg Middle School

Linn_sch40C

Enrollment 189	Year Built (Field Verified) 1936	Year Built (Alt. Source) 1936	Est. Decade Built 1950
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Out of Plane Lateral-Force-Resistance Elements		None	
Reentrant Corners: L Shaped		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	

Harrisburg Middle School

Harrisburg SD 7J

Linn_sch40D

Building Type School	County Linn	
Street 201 S 6th st		
City Harrisburg	State OR	Zip 97446
Latitude 44.27148	Longitude 123.16521	
Tracking Code RVS in 2006	Inspection Date 7/31/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Harrisburg Middle School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Harrisburg Middle School

Linn_sch40D

Enrollment 189	Year Built (Field Verified) 1936	Year Built (Alt. Source) 1970	Est. Decade Built 1970
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
			
S Vertical Irregularity Primary		N Plan Irregularity Primary also shows the covered play ground. Step in elevation	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Harrisburg Middle School

Harrisburg SD 7J

Linn_sch40E

Building Type	County
School	Linn
Street	
642 Smith St	
City	State Zip
Harrisburg	OR 97446
Latitude	Longitude
44.27202	123.16435
Tracking Code	Inspection Date
RVS in 2006	7/31/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Harrisburg Middle School

Final RVS Score

Final Type	Final Score
RM1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Harrisburg Middle School

Linn_sch40E

Enrollment 189	Year Built (Field Verified) 1993	Year Built (Alt. Source) 1936	Est. Decade Built 1990
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Plan Irregularity Primary			

Harrisburg Middle School

Harrisburg SD 7J

Linn_sch40F

Building Type	County
School	Linn
Street	
642 Smith St	
City	State Zip
Harrisburg	OR 97446
Latitude	Longitude
44.27195	123.16531
Tracking Code	Inspection Date
RVS in 2006	7/31/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	0	0	0	0	-0.6	0	1.2
Secondary	W2	3.8	-2	0	0	0	0	-0.8	0	1
Tertiary		0	0	0	0	0	0	0	0	0

Harrisburg Middle School

Final RVS Score

Final Type	Final Score
W2	1

FEMA-154 Collapse Potential

High (>10%)



Harrisburg Middle School

Linn_sch40F

Enrollment 189	Year Built (Field Verified) 1959	Year Built (Alt. Source) 1936	Est. Decade Built 1950
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
			
N Plan Irregularity Primary		E Vertical Irregularity Primary	