

Takena Elementary School

Greater Albany SD 8J

Linn_sch44A

Building Type		County	
School		Linn	
Street			
1210 12th Ave SW			
City	State	Zip	
Albany	OR	97321	
Latitude		Longitude	
44.62686		123.11922	
Tracking Code		Inspection Date	
Hasenberg 02		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	0	-0.8	0	3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Takena Elementary School

Final RVS Score

Final Type

Final Score

W2

3

FEMA-154 Collapse Potential

Low (<1%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
134		1971	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
31393	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions