

Mari-Linn Elementary School

Linn_sch45A

North Santiam SD 29J

Building Type		County	
School		Linn	
Street			
641 5th St			
City	State	Zip	
Lyons	OR	97358	
Latitude		Longitude	
44.77922		122.61708	
Tracking Code		Inspection Date	
RVS in 2006		6/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mari-Linn Elementary School

Final RVS Score

Final Type

Final Score

RM1

-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mari-Linn Elementary School

Linn_sch45A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
234		1948	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
29687	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: U shaped	Steps in Elevation View: 2 to 3 Changes
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NE General Site



S Primary Structural Type



W Plan Irregularity Primary



W Vertical Irregularity Primary



NW Primary Structural Type

Mari-Linn Elementary School

Linn_sch45B

North Santiam SD 29J

Building Type		County	
School		Linn	
Street			
641 5th St			
City	State	Zip	
Lyons	OR	97358	
Latitude		Longitude	
44.77894		122.6175	
Tracking Code		Inspection Date	
RVS in 2006		6/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mari-Linn Elementary School

Final RVS Score

Final Type

Final Score

C2

-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
234		1948	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
29687	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



E Vertical Irregularity Primary
reentrant corner